

On behalf of
The City of Siloam Springs, AR - 2027 Chemicals Bid

ADDENDUM 1

October 19, 2026

A signed copy of this addendum should be included with your submission.

Name: _____

Signature: _____ Company: _____

Vendors are informed that the above subject Electronic Sealed Bid Event is hereby modified, corrected or supplemented as specified, described and set forth in this document.

SODIUM THIOSULFATE 30%: The City of Siloam Springs estimates purchasing up to ~~30,000 gallons or 320,000 pounds~~ **40,000 gallons or 426,000 pounds** of Sodium Thiosulfate 30% during the 2027 calendar year. The specified product must be delivered to the Siloam Springs Wastewater Treatment Plant (SSWWTP), via tanker truck. The supplier's quoted price for Sodium Thiosulfate 30% shall remain the same for 2027 calendar year.

Properties of Sodium Thiosulfate 30%:

1. Appearance: Clear, colorless to pale yellow
2. Odor: sulfur like
3. Specific Gravity: 1.26-1.50
4. Solubility in water: Dilutable
5. Boiling point: 217 degrees Fahrenheit
6. Freezing point: 14 degrees Fahrenheit
7. pH: 8.0-11.0%
8. % Volatiles by Vol.: N/A
9. Weight: ~~29.0-31.0~~ **10.5-12.5**

Questions and Answers:

- 1) Could you please confirm the current price being paid for ACH (aluminum chlorohydrate) under the current contract?

ANSWER: \$0.4500/WET POUND

- 2) Do you know what load size is needed for deliveries on the Sodium Thiosulfate? Bid is giving specs and annual usage but not the size of a load each.

ANSWER: 45,000 POUNDS